

CERTIFICATE OF CONFORMITY

This Certificate is issued to
SOLARGY HOLDINGS PTE LTD
(UEN No.: 201025116N)
20 SIN MING LANE, #04-65 MIDVIEW CITY, SINGAPORE (573968)

For Product Certification Scheme: Type 5

Product : Solar Photo-Voltaic (PV) Roof-Mounted Module

Brand : Jolywood

Model	Model	No. of Cells	Dimension (mm)
	JW-HD144N-xxx (xxx = 565 - 590, in steps of 5)	144	2278 x 1134 x 30
	JW-HD108N-xxx (xxx = 415 - 440, in steps of 5)	108	1722 x 1134 x 30
	JW-HD156N-xxx (xxx = 610 - 635, in steps of 5)	156	2465 x 1134 x 30

**with Junction Box (JWPV-01a) and Solar Cables
(62930 IEC 131, 1x4mm², 1x6mm²)**

Country of Origin : China

**Product Details : Double Glass, ½ cut N-type Bifacial Mono-crystalline
Photovoltaic Module
Maximum System Voltage: 1500VDC
Fire Rating: Class A
Fire Classification: Class B with FIGRA < 70 W/s
accordance to EN 13501-1**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
IEC 61730-1:2016	TUV Sud Report No.: 704061930402-19 Part 2 of 2
IEC 61730-2:2016	TUV Nord Test Report No.: TRPVP07117/23P/03
EN 13501-1: 2018	TUV Nord Classification Report No.: TRPVP11098/22P/01_R1



Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd

Certificate No

FSP-2024-1530

Date of Issue

29/05/2024

Date of Expiry

28/05/2029

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.