ATESTACIÓN



Attestation of Conformity

No. N8A 098081 0013 Rev. 11

Holder of Attestation:	Jolywood (Taizhou) Solar Technology Co., Ltd. Kaiyang Rd.Jiangyan Economic Development Zone 225500 Taizhou City,Jiangsu Province PEOPLE'S REPUBLIC OF CHINA
Product:	Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.:

704061930402-20

Date,

2024-05-27

gztis

(Zhulin Zhang)

Page 1 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

BESCHEINIGUNG

ATESTACIÓN



Attestation of Conformity

No. N8A 098081 0013 Rev. 11

Model(s):

JW-D72N-xxx, xxx= 365-410, in steps of 5 JW-D60N-xxx, xxx= 305-340, in steps of 5 JW-HD144N-xxx,xxx=390-420, in steps of 5 JW-HD120N-xxx, xxx=325-350, in steps of 5 JW-HD144P-xxx, xxx=390-415, in steps of 5 JW-HD120P-xxx, xxx=325-345, in steps of 5 JW-HD156N-xxx, xxx=425-455, in steps of 5 JW-HD156P-xxx, xxx=425-445, in steps of 5 JW-HD144N-xxx, xxx=430-470, in steps of 5 JW-HD120N-xxx, xxx=360-390, in steps of 5 JW-HD144P-xxx, xxx=430-450, in steps of 5 JW-HD120P-xxx, xxx=360-375, in steps of 5 JW-HD144N-xxx. xxx=525-590, in steps of 5 JW-HD144N-xxxS, xxx=545-590, in steps of 5 JW-HD108N-xxx, xxx=395-445, in steps of 5 JW-HD108N-xxxS, xxx=415-445, in steps of 5 JW-HD156N-xxx, xxx=580-635, in steps of 5 JW-HD156N-xxxS, xxx=610-635, in steps of 5 JW-HT156N-xxx, xxx=580-635, in steps of 5 JW-HT156N-xxxS, xxx=610-635, in steps of 5 JW-HT144N-xxx, xxx=525-590, in steps of 5 JW-HT144N-xxxS, xxx=545-590, in steps of 5 JW-HT108N-xxx, xxx=395-445, in steps of 5) JW-HT108N-xxxS, xxx=415-445, in steps of 5) JW-HD120N-xxx, JW-HD120N-xxxS, xxx=435-490, in steps of 5 JW-HD144P-xxx, JW-HD144P-xxxS, xxx=525-555, in steps of 5 JW-HD120P-xxx, JW-HD120P-xxxS, xxx=435-460, in steps of 5 JW-HD132N-xxx, JW-HD132N-xxxS, xxx=485-540, in steps of 5 JW-HD132P-xxx, JW-HD132P-xxxS, xxx=485-505, in steps of 5 JW-HD108P-xxx, JW-HD108P-xxxS, xxx=395-415, in steps of 5 JW-HD120P-xxx, JW-HD120P-xxxS, xxx=580-610, in steps of 5 JW-HD120N-xxx, JW-HD120N-xxxS, xxx=580-655, in steps of 5 JW-HD132N-xxx, JW-HD132N-xxxS, xxx=655-715, in steps of 5 JW-HD156P-xxx, JW-HD156P-xxxS, xxx=580-605, in steps of 5 JW-HT132N-xxx, JW-HT132N-xxxS, xxx=480-530, in steps of 5 JW-HT120N-xxx, JW-HT120N-xxxS, xxx=440-480, in steps of 5 JW-HT156P-xxx, JW-HT156P-xxxS, xxx=580-605, in steps of JW-HT144P-xxx, JW-HT144P-xxxS, xxx=525-555, in steps of 5 JW-HT132P-xxx, JW-HT132P-xxxS, xxx=480-505, in steps of 5 JW-HT120P-xxx, JW-HT120P-xxxS, xxx=440-455, in steps of 5 JW-HT108P-xxx, JW-HT108P-xxxS xxx=395-415, in steps of 5 JW-HD156N-R0-xxx, JW-HD156N-R0-xxxS, xxx=610-645, in steps of 5 JW-HD144N-R0-xxx, JW-HD144N-R0-xxxS, xxx=570-595, in steps of 5 JW-HD108N-R0-xxx, JW-HD108N-R0-xxxS, xxx=420-450, in steps of 5 JW-HD120N-R3-xxx, JW-HD120N-R3-xxxS, xxx=480-515, in steps of 5

Page 2 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

ESCHEINIGUNG

m

ATESTACIÓN

ESCHEINIGUNG

m



Attestation of Conformity

No. N8A 098081 0013 Rev. 11

JW-HD108N-R3-xxx, JW-HD108N-R3-xxxS, xxx=430-460, in steps of 5 JW-HD144N-R1-xxx, JW-HD144N-R1-xxxS, xxx=595-625, in steps of 5 JW-HD120N-R1-xxx, JW-HD120N-R1-xxxS, xxx=495-525, in steps of 5 JW-HD108N-R1-xxx, JW-HD108N-R1-xxxS, xxx=445-470, in steps of 5 JW-HD132N-R2-xxx, JW-HD132N-R2-xxxS, xxx=595-625, in steps of 5 JW-HD120N-R2-xxx, JW-HD120N-R2-xxxS, xxx=540-570, in steps of 5 JW-HD108N-R2-xxx, JW-HD108N-R2-xxxS, xxx=485-515, in steps of 5 JW-HD96N-R2-xxx, JW-HD96N-R2-xxxS, xxx=430-460, in steps of 5 JW-HT156N-R0-xxx, JW-HT156N-R0-xxxS, xxx=615-645, in steps of 5 JW-HT144N-R0-xxx, JW-HT144N-R0-xxxS, xxx=570-600, in steps of 5 JW-HT108N-R0-xxx, JW-HT108N-R0-xxxS, xxx=420-450, in steps of 5 JW-HT120N-R3-xxx, JW-HT120N-R3-xxxS, xxx=480-510, in steps of 5 JW-HT108N-R3-xxx, JW-HT108N-R3-xxxS, xxx=430-460, in steps of 5 JW-HT144N-R1-xxx, JW-HT144N-R1-xxxS, xxx=595-625, in steps of 5 JW-HT120N-R1-xxx, JW-HT120N-R1-xxxS, xxx=495-520, in steps of 5 JW-HT108N-R1-xxx, JW-HT108N-R1-xxxS, xxx=445-470, in steps of 5 JW-HT132N-R2-xxx, JW-HT132N-R2-xxxS, xxx=595-625, in steps of 5 JW-HT120N-R2-xxx, JW-HT120N-R2-xxxS, xxx=540-570, in steps of 5 JW-HT108N-R2-xxx, JW-HT108N-R2-xxxS, xxx=485-515, in steps of 5 JW-HT96N-R2-xxx, JW-HT96N-R2-xxxS, xxx=430-455, in steps of 5) xxx stands for rated output power at STC

Page 3 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

ATESTACIÓN



Attestation of Conformity

No. N8A 098081 0013 Rev. 11

Parameters:

Construction: Safety Class:

Framed or frameless, with Junction box, Cable and Connectors. Class II Maximum System Voltage: 1500 V DC

Fire Safety Class:

Test Laboratory:

Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.

Class A or Class C according to UL 790

Tested according to: EN IEC 61730-1:2018 EN IEC 61730-1:2018/AC:2018-06 EN IEC 61730-2:2018 EN IEC 61730-2:2018/AC:2018-06

Page 4 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

BESCHEINIGUNG